



GENERAL NOTES

1. SPECIAL BACKFILL MATERIAL FOR DRYWELLS SHALL CONSIST OF WASHED GRAVEL, GRADED FROM 1" TO 3" WITH A MAXIMUM OF 5% PASSING THE U.S. No. 200 SCREEN, AS MEASURED BY WEIGHT.
GRAVEL BACKFILL QUANTITY FOR DRYWELLS:
TYPE "A" - 30 CUBIC YARDS MINIMUM
TYPE "B" - 40 CUBIC YARDS MINIMUM
OR AS SPECIFIED ON PLANS.
2. ADJUSTMENT BLOCKS SHALL BE CEMENT CONCRETE. ONE BLOCK MINIMUM REQUIRED.
3. SEE STANDARD DRAWING SS-2 FOR FRAME AND COVER DETAIL.

REVISION	APPROVED	DATE

CITY OF COEUR D'ALENE STANDARD DRAWING

APPROVED BY:

TYPE B DRYWELL

John Miller
CITY ENGINEER, PE 7432
DATE: 4/1/08

DWG NO. SD-6B