



**SECTION**

**NOTES**

1. For trenching in improved streets, see Standard DrawingM-11 for trench resurfacing.
2. (\*) indicates minimum relative compaction using modified proctor (ASTM D-1557).
3. Bedding Material shall be Sand, Gravel, crushed Aggregate, or Native Granular material having a sand equivalent of not less than 30.

REVISION	APPROVED	DATE	CITY OF COEUR D'ALENE STANDARD DRAWING	APPROVED BY:
			<b>PIPE BEDDING AND BACKFILL FOR STORM DRAINS</b>	 CITY ENGINEER, PE 7432 DATE: 4/1/08