



Subgrade compacted to 95%.

4" of 3/4" minus crushed rock base
Compacted to 95% of modified proctor.

No scale

NOTES:

1. Weakened Plane Joints every ten (1) feet with Expansion Joint filler at curb returns and every one hundred (100) feet. Refer to Standard Drawing **C-5**.
2. When existing curb is removed care will be taken not to disturb existing asphalt pavement. Refer to Standard Drawing **M-11** for asphalt street patching.
3. Joints between existing and new curb will be sawed.
4. A light broom finish is required.
5. Compressive Strength of Concrete shall be 3000 PSI minimum.
6. Installation of rolled curb and gutter must be approved in writing by the City Engineer.

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:
			ROLLED CURB AND GUTTER	 CITY ENGINEER, PE 7432
				DATE: 4/20/15
				DWG NO. C-3