

1. Location and elevation of existing facilities should be confirmed by field measurements and excavation exploration by the contractor, prior to beginning of new work. All work is to conform to OSHA requirements.
2. Wastewater Utility does not respond to the "One-Call" notification. Contractor must call separately for locates on Sanitary Sewer. (208) 769-2241.
3. Each lot shall be served by minimum of a single four (4) inch (residential), or six (6) inch (commercial) sewer lateral set at a minimum of 2.0%. See Std. Dwg. SS-6. All sewer laterals shall be shown on as-built plans with stationing and elevations.
4. Sanitary sewer laterals shall be at right angles to public sewer mains, except in a cul-de-sac where the (90°) rule is not practical. Cul-de-sac laterals may enter manholes with prior approval. Sewer service connections shall be tees for all public mains. Private service connections shall conform to the plumbing code.
5. The contractor must secure approval from the City's Engineering Inspector prior to backfill over sewer tees and laterals.
6. No disruption of existing sanitary sewer service will be allowed without the specific approval of the City's Wastewater Utility.
7. The Engineer of Record shall notify the City's Engineering Inspector and Wastewater Utility at least forty-eight (48) hours prior to commencing work on any public sewers.
8. All public sewer mains and sewer laterals shall be placed, inspected, tested, and approved by the City prior to paving.
9. All public sanitary sewer lines shall be CCTV and submitted on CD in a usable formatted template using "POSM" or another pre-approved equivalent program to the City's Wastewater Utility for review and approval prior to paving. The Wastewater Utility will provide a copy of the template upon request. Please allow forty-eight (48) hours for review.
10. All sanitary manholes shall be inspected by the Wastewater Utility, first inspection prior to paving and second inspection prior to acceptance of improvements. Call (208) 769-2241 for inspection scheduling.
11. All sanitary sewer mains shall be air tested in accordance with Idaho Standards for Public Works Construction (ISPWC). Testing shall be witnessed, recorded, and signed by the Engineer of Record and the test results submitted to the City's Engineering Inspector.

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:
		3/31/15	<h1 style="margin: 0;">SEWER SYSTEM</h1> <h2 style="margin: 0;">NOTES</h2>	 CITY ENGINEER, PE 7432
				4/20/15 DATE:
				DWG NO. M-26