



DRYWELL - TYPE 'A'

GENERAL NOTES

1. SPECIAL BACKFILL MATERIAL FOR DRYWELLS SHALL CONSIST OF WASHED GRAVEL GRADED FROM 1" TO 3" WITH A MAXIMUM OF 5% PASSING THE U.S. No. 200 SCREEN, AS MEASURED BY WEIGHT.

GRAVEL BACKFILL QUANTITY FOR DRYWELLS:  
 TYPE "A" - 30 CUBIC YARDS MINIMUM  
 TYPE "B" - 40 CUBIC YARDS MINIMUM  
 OR AS SPECIFIED ON PLANS.

2. ADJUSTMENT BLOCKS SHALL BE CEMENT CONCRETE. ONE BLOCK MINIMUM REQUIRED.  
 3. SEE STANDARD DRAWING SS-2 FOR FRAME AND COVER DETAIL.

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:	
				<b>TYPE A DRYWELL</b>	<i>Robert Debes</i>
			CITY ENGINEER, PE 7432		DATE:
			DWG NO.		SD-6A