


## THRUST BLOCK BEARING AREA



### NOTES

1. Based on 150 psi test pressure and a soil bearing pressure of 1500psf
2. For conditions not covered by these curves, special thrust blocks must be designed and approved.
3. Ecology blocking may be used with prior approval from the City Engineer and/or the Superintendent for mains 12" and less in size.
4. The Design Engineer shall provide thrust bearing area calculations using 1500psf as the desired standard prior to block approval.

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:	
				<i>[Signature]</i>	4/20/15
			<b>THRUST BLOCK BEARING AREA</b>	CITY ENGINEER, PE 7432	DATE:
				DWG NO.	W-10