



NO BYPASS
REQUIRED FOR
IRRIGATION
INSTALLATION

SEE METER VAULT DETAIL W-17
USE 1914 SERIES WILBERT VAULT

FLANGED PIPE, 4"
MINIMUM, WILL BE
RESTRAINED TO LAST
MECHANICAL JOINT
AT TEE. DO NOT USE
VAULT WALL AS
THRUST BEARING
SURFACE.

PLAN NOTES:

GATE VALVE TO BE
INSTALLED AT HOT
TAP TO WATER MAIN

3" OR LARGER
METER IN VAULT
WILL BE RADIO READ

PLAN VIEW

REVISION	APPROVED	DATE

CITY OF COEUR d'ALENE STANDARD DRAWING

**3" AND LARGER METER SETTING/
IRRIGATION VAULT**

APPROVED BY:

Andon J. Jolley
CITY ENGINEER, PE 7432

4/20/15
DATE:

DWG NO.

W-16