



**NOTES**

1. When distance from hydrant to the top or toe of slope is less than 2 feet special installation will be required by the City Engineer.
2. Where hydrant is not protected by a vertical face of curb protective posts are required.
3. The centerline of the hydrant shall be located 5' minimum from curb return and minimum 5' from driveway or any fixed obstruction.

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:
			<h1 style="margin: 0;">FIRE HYDRANT LOCATIONS</h1>	 CITY ENGINEER, PE 7432
				4/20/15 DATE:
				DWG NO.      W-4