



NOTES:

1. This plan does not apply for new sidewalk construction in undeveloped areas.
2. 5-foot transition panels are required when cross slope of adjacent existing walk exceeds 2.0%.
3. Root areas shall be undisturbed as much as practical. Loose soil shall be lightly hand tamped. If root trimming is necessary, contact the City Urban Forestry department.
4. Typical sidewalk diversion angle shall be 2.5 to 1. The diversion angle may be increased to 1 to 1 as directed by the engineer.
5. Back of sidewalk shall be a minimum of 0.5 ft inside of the right-of-way. Sidewalk width may be decreased to 3 ft as directed by the Engineer to ensure sidewalk is within the right-of-way.
6. Use in conjunction w/ Std Dwg C-18 when ramping over and diverting around tree roots is required.
7. See Std Dwg C-5 for general sidewalk requirements. Provide additional expansion joints as shown.
8. Place topsoil and hydroseed or sod as directed by the Engineer.
9. Relocate or replace existing sprinkler systems as needed.
10. 1.0% minimum cross slope and 2.0% maximum cross slope. No additional construction tolerance is allowed.

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:
			SIDEWALK REPAIR DIVERSION AT TREES	<i>Chris Buehler</i> 6/20/18
				CITY ENGINEER, PE 10804 DATE:
			DWG NO.	C-19