

10. All existing public sanitary sewer connections, modifications and extensions require the City Wastewater Utility's inspection and approval at least 48 hours prior to backfill. Call 208.769.2213. Any scheduled requests not ready for inspection will require another 48-hour inspection notification.

11. All private sewers and sewer lateral replacement/repairs shall conform to the City's adopted Idaho State Plumbing Code and require the City Building Department's inspection and approval prior to backfill. Call 208.769.2391.

12. All new sanitary sewer construction shall require the following prior to the City Wastewater Utility's final approval and acceptance of sewer improvements:
 - a. All sanitary sewer tees and laterals shall be inspected and approved by City Inspectors at least 48 hours prior to backfill. Call 208.769.2285, and;

 - b. All sewer lines, lateral connections, vaults and manhole structures shall be cleaned of any debris prior to pavement. Hydrant flushing of debris into downstream sewers is not acceptable means of cleaning, and;

 - c. All sanitary sewer lines shall be pressure tested in accordance with the latest edition of the Idaho Standards for Public Works Construction (ISPWC) and City Standards. All testing shall be witnessed, recorded and signed off by City Inspectors prior to pavement. Call 208.769.2285, and;

 - d. All tracer wires shall be tested and locate painted for continuous continuity and witnessed and signed off by City Inspectors prior to sub grade approval. Call 208.769.2213, and;

 - e. All public sanitary sewer lines shall be CCTV and submitted on DVD in a usable formatted template using "POSM" or another pre-approved equivalent program to the City Wastewater Utility's for review and approval prior to pavement. Please allow 48 hours for review. Call 208.769.2213, and;

 - f. All sanitary sewer vaults and manhole structures shall be adjusted to finish grade per City Standard Drawings and inspected and approved by the City Wastewater Utility prior to pavement and immediately after pavement (2 Inspections Required) Call 208.769.2213, and;

 - g. Secure authorization from the City Inspectors to clean out and dispose of all debris and remove the plug installed at the beginning of this sewer project at the lowest sanitary sewer manhole pipe inlet(s).

13. All sanitary sewer lines shall be separated at least 10 feet horizontally and a minimum 18-inch vertical separation with domestic water lines. Any anticipated separation differing from the minimum standards contained herein shall conform to IDAPA 58.01.16.



CITY OF COEUR D'ALENE STANDARD DRAWING

SEWER SYSTEM NOTES
PAGE 2

APPROVED BY:

Chris Bosley
CITY ENGINEER, PE 10804

10/1/24
DATE:

DWG NO.

M-29