



DRYWELL - TYPE 'B'

NOTES

1. SPECIAL BACKFILL MATERIAL FOR DRYWELLS SHALL CONSIST OF WASHED GRAVEL GRADED FROM 1" TO 3" WITH A MAXIMUM OF 5% PASSING THE U.S. No. 200 SCREEN, AS MEASURED BY WEIGHT.

GRAVEL BACKFILL QUANTITY FOR DRYWELLS:
 TYPE "A" - 30 CUBIC YARDS MINIMUM
 TYPE "B" - 40 CUBIC YARDS MINIMUM
 OR AS SPECIFIED ON PLANS.

2. ADJUSTMENT BLOCKS SHALL BE CEMENT CONCRETE. ONE BLOCK MINIMUM REQUIRED.
 3. SEE STANDARD DRAWING SS-5 FOR FRAME AND COVER DETAIL.



CITY OF COEUR D'ALENE STANDARD DRAWING

TYPE B DRYWELL

APPROVED BY:

Chris Bosley
 CITY ENGINEER, PE 10804

10/1/24
 DATE:

DWG NO.

SD-6B