



SECTION

Not to Scale

NOTES

1. For trenching in improved streets, see Standard Drawing M-11 for trench resurfacing.
2. (*) indicates minimum relative compaction using modified proctor (ASTM D-1557).
3. Bedding Material shall be Sand, Gravel, crushed Aggregate, or Native Granular material having a sand equivalent of not less than 30.



CITY OF COEUR D'ALENE STANDARD DRAWING

**PIPE BEDDING & BACKFILL
FOR STORM DRAINS**

APPROVED BY:

Chris Bosley
CITY ENGINEER, PE 10804

10/1/24
DATE:

DWG NO.

SD-8