



NOTES

1. When distance from hydrant to the top or toe of slope is less than 2 feet special installation will be required by the City Engineer.
2. Where hydrant is not protected by a vertical face of curb protective posts are required.
3. The centerline of the hydrant shall be located 5' minimum from curb return and 5' minimum from a driveway or any fixed obstruction.

REVISION	APPROVED	DATE	CITY OF COEUR d'ALENE STANDARD DRAWING	APPROVED BY:
			<i>FIRE HYDRANT LOCATIONS</i>	<i>Chris Bodley</i> CITY ENGINEER, PE 10802
				DWG NO. W-4
				4/13/13 DATE: