



PLAN VIEW

NOTES:

1. GATE VALVE TO BE INSTALLED AT HOT TAP TO WATER MAIN
2. 3" OR LARGER METER IN VAULT WILL BE RADIO READ

SEE METER VAULT DETAIL W-17
USE 1914 SERIES WILBERT VAULT



CITY OF COEUR D'ALENE STANDARD DRAWING
**4" & LARGER SERVICE SETTING
 SETTING IRRIGATION VAULT**

APPROVED BY:
Chris Boddy
 CITY ENGINEER, PE 10604
 DATE: 10/1/24
 DWG NO. W-16