



**NOTE:**

1. NO BLOW OFF PORTS ARE ALLOWED UPSTREAM OR DOWNSTREAM OF THE AVB. THE DEVICE MUST BE REMOVED FROM THE SYSTEM PRIOR TO BLOWING OUT THE IRRIGATION SYSTEM.
2. NO MANUAL OR AUTOMATIC VALVES ALLOWED DOWNSTREAM OF AVB.
3. AVB CANNOT BE PRESSURIZED MORE THAN 12 HOURS IN A 24 HOUR PERIOD.



CITY OF COEUR D'ALENE STANDARD DRAWING

**APPROVED ATMOSPHERIC  
VACUUM BREAKER INSTALL**

APPROVED BY:

*Chris Bosley*  
CITY ENGINEER, PE 10804

10/1/24  
DATE:

DWG NO.

W-22